SUMMARY OF COLIFORM TESTS CONDUCTED FOR TYBOUTS CORNER LANDFILL PROJECT

1970

000234

TOTAL COLIFORM COUNT PER 100 ML.											
SAMPLING STATION											
	STREAMS*						RESIDENCES**				
DATE	S2	S3	S4	S9	S6	S8	Wolfe	Webb	Baker	McCafferty	Ford
1/5	>100	1	>100	>100	>100	>100	85	212	NS	900	0
1/25	48	NS	95	45	60	>100	20	160	NS	80	NS
2/23	33	9	66	46	36	40	NS	51	4	148	0
3/30	---	---	---	---	---	---	1	170	0	NS	0

*All Stream Total Coliform Counts are reported as thousands per 100 ml.

NS - not sampled

**State Board of Health was notified of positive coliform counts obtained from domestic drinking water supply samples.

GPRasmussen/pw
5/13/71

027906

(1)